

Level 1 Validation – Water Supplier Confirmation

This document confirms participation in and endorsement of the Level 1 Validation as completed.

This acknowledgement is required for submission – alongside your Level 1 validated water audit software file – to the California Department of Water Resources.

Water Supplier Name: Yorba Linda Water District

Water Supplier Public Water System ID: CA3010037

Water Audit Period: 2017

Water Audit & Water Loss Improvement Steps

Steps taken in the audit period timeframe to increase data source accuracy, reduce real losses, and/or reduce apparent losses, as informed by the water audit.

YLWD investigates anomalies and utilizes SCADA. YLWD owns an in-house test bench used to test flagged meters. Large meters are tested by a neighboring agency. YLWD has set protocols within their operations group where any operational use is monitored and logged, daily. YLWD owns and operates their own leak detection equipment to survey their system.

Certification Statement by Water Supplier Executive:

This water loss audit report meets the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34 and has been prepared in accordance with the method adopted by the American Water Works Association, as contained in their manual, *Water Audits and Loss Control Programs, Manual M36, Fourth Edition* and in the Free Water Audit Software version 5.

Executive Name (print): Marc Marcantonio

Executive Position: General Manager

Signature: 

Date: September 19, 2018